

**WARDFLEX UL Through Penetrating Firestop Listings**

System No	Rating hr		Firecaulk Prod	Remove Coverir	Max Size	Max Quantit
	F	T				
C-AJ-1217	3 and 4	0	5		2	1
C-AJ-1225	2	0	1	R	2	1
C-AJ-1240	2 and 3	0	6		3	1
C-AJ-1327	3	2 and 3	2		1-1/4	1
C-AJ-1328	3	2 and 3	3		1-1/4	1
C-AJ-1329	3	2	2		1-1/4	3
C-AJ-1330	3	2	3		1-1/4	3
C-AJ-1346	2	0	9		1	1
C-AJ-1353	3	0	4		2	1
C-AJ-1354	2	0	4		2	>1
C-AJ-1427	2	0	7		1	1
C-AJ-1428	2	0	7		1	1
C-AJ-1429	2	0	7		1	>1
C-AJ-1513	2	0	9		2	1 OR MORE
C-AJ-1522	3	0	15		2	1
C-AJ-1551	2	0	1, 7, 10,		1	1
C-AJ-1553	1 and 2	0	12		1	3
C-AJ-1556	2	0	1, 10, 13, 16		1	1 OR MORE
C-BJ-1059	3	3	9		1	8
F-C-1029	1 and 2	1	1	R	2	1
F-C-1055	1	1	2		1	1
F-C-1056	1	1	3		2	1
F-C-1061	1/4 and 1	1/4 and 1	2		1-1/2	1
F-C-1062	1/4 and 1	1/4 and 1	3		1-1/2	1
F-C-1063	1 and 2	1 and 2	2		1-1/4	1
F-C-1064	1 and 2	1 and 2	3		1-1/4	1
F-C-1065	1 and 2	1 and 2	2		1-1/4	3
F-C-1066	1 and 2	1 and 2	3		1-1/4	3
F-C-1074	1 and 2	1/4, 1/2 & 1	4		2	1
F-C-1075	1 and 2	1/4, 1/2 & 1	4		1	>1
F-C-1094	1	1/4	7		1	1
F-C-1095	1	3/4	7		1	1
F-C-1138	1	1	16		2	1
F-C-1139	1	1	16		1-1/4	1
F-C-1140	1	0	11		2	1
F-C-1141	1	1	16		1-1/4	1
F-C-1147	1	1	9, 17		1	3
F-E-1002	1	1	4		2	1
F-E-1003	1	1	4		1	>1
F-E-1009	1	1/4	7		1	1
F-E-1010	1	3/4	7		1	1
F-E-1018	1	1	9, 17		1	3
F-E-1019	1	1/4	12, 18		1	1
W-J-1079	2	2	2		1-1/4	1
W-J-1080	2	2	3		1-1/4	1
W-J-1081	2	2	2		1-1/4	3
W-J-1082	2	2	3		1-1/4	3
W-J-1098	2	1	4		1-1/4	1
W-J-1099	2	1	4		2	1
W-J-1101	2	1	4		2	>1
W-J-1122	2	1/4	7		1	>1
W-J-1127	2	1/4	7		1	1
W-L-1001	VARIES	VARIES	1		1	1
W-L-1096	2	0	1	R	2	1
W-L-1179	1 and 2	1 and 2	2		1-1/4	1
W-L-1180	1 and 2	1 and 2	3		1-1/4	1
W-L-1181	1 and 2	1 and 2	2		1-1/4	3
W-L-1182	1 and 2	1 and 2	3		1-1/4	3
W-L-1195						
W-L-1198	2	2	16		1-1/4	1
W-L-1199	1 and 2	1 and 2	2		1-1/4	1
W-L-1200	1 and 2	1 and 2	3		1-1/4	1
W-L-1222	1	1/4, 3/4 & 1	4		1-1/4	1
W-L-1223	1	1	4		2	1
W-L-1224	1	2	4		2	>1
W-L-1243	1 and 2	0	9		1	1
W-L-1287	1 and 2	0 & 1/4	7		1	>1
W-L-1296	1 and 2	0 & 1/4	7		1	1
W-L-1369	1 and 2	1	15		2	1 OR MORE
W-L-1396	1 and 2	1 and 2			1-1/4	1
W-L-1400	1 and 2	1 and 2			1-1/4	1
W-L-1407	2 and 2	0	12		1	3
W-L-1414	1 and 2	0	1, 10		1	1 OR MORE
W-L-8071	1 and 2	0	9		2	1 OR MORE

System No. explanations:  
 First alpha:  
 F = floor is being penetrated,  
 W = wall,  
 C = walls or floors  
 E = Floor-ceiling assemblies con  
 with membrane pro  
 Second alpha"  
 A = concrete flic  
 les

Rating hours:  
 F = flame passage criteria  
 T = temperature rise of 325°F

Consult UL Fire Resistance Directory - Volume 2 for  
 construction details or contact WARD MAI

Firecaulk Products  
 1 3M COMPANY: CP-25-WB+  
 2 Rectorseal: Metacaulk 1000  
 3 Rectorseal: Biostc  
 4 Specified Technology  
 5 Specified Tech

These can be downloaded directly from UL's w  
<http://database.ul.com/cgi-bin/XYV/template/LISEXT/>

**DISCONTINUED SYSTEM NUMBERS**

C-AJ-1437	3	2 and 3	8		1-1/4	1
C-AJ-1438	3	2	8		1-1/4	3
F-C-1077	1	1	8		1-1/4	1
F-C-1078	1	1/4 and 1	8		1-1/4	1
F-C-1079	1 and 2	1 and 2	8		1-1/4	1
F-C-1080	1 and 2	1 and 2	8		1-1/4	3
W-J-1104	2	1	8		1-1/4	1
W-J-1105	2	2	8		1-1/4	3
W-L-1241	1 and 2	1 and 2	8		1-1/4	3
W-L-1295	1 and 2	1 and 2	8		1-1/4	1